



Overheat: This device is a safety device and must be set as guided by the heater manual. Failure to do so could cause damage to this heater, injury to persons or property.

BMM Heaters Ltd
 1 Copeland Court
 Forest Grove
 Riverside Park
 Middlesbrough
 TS2 1RN
 Tel: 01642 240700
 Fax: 01642 240708
 Sales@bmmheaters.co.uk

Drawing By: S.Byrne

Customer:

Date: 1/12/06

Scale: N/A

Project Ref:

Drawing No: RS Riello PLUGS

Description: Modulating Heater using direct wiring to the burner.

Supplies Required by others:
 Burner Control: 240vac 50Hz
 Burner Modulation: 0-10vdc

Symbol Info:
 EN: Burner Enable
 S3: Burner lockout
 B4: Burner Run Ind

By Others
 S: External Fault Indication Lamp.
 R: External Burner Run Indication Lamp.